

TEST REPORT

Application No.: SHEM2405002833BA
Applicant: RelyEZ Energy Storage Technology Co., Ltd.
Address of Applicant: A3603 Building 11A, Shenzhen Bay Science and Technology Ecological Park, No.16 Keji South Road Nanshan District, Shenzhen, Guangdong, China
Manufacturer: Jiangsu RelyEZ Energy Storage Technology Co., Ltd.
Address of Manufacturer: 130 Tonggang Road, New District, Zhenjiang, Jiangsu, China
Factory: Jiangsu RelyEZ Energy Storage Technology Co., Ltd.
Address of Factory: 130 Tonggang Road, New District, Zhenjiang, Jiangsu, China
Equipment Under Test (EUT):
EUT Name: ESS(VenturePro 250)
Model No.: YXYK-125K/552314-L
Standard(s) : EN IEC 61000-6-4:2019
EN IEC 61000-6-2:2019
Date of Receipt: 2024-07-10
Date of Test: 2024-07-10
Date of Issue: 2024-07-24

Test Result	Pass*
--------------------	--------------

* In the configuration tested, the EUT complied with the standards specified above.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.





SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd.

SHEM-TRF-001 Rev. 02 Sep01, 2023

Report No.: SHEM240500283301

Page: 2 of 45

Revision Record			
Version	Description	Date	Remark
00	Original	2024-07-24	/

Authorized for issue by:			
Tested By			
	Andy Yang / Project Engineer		
Approved By			
	Parlam Zhan / Reviewer		

2 Test Summary

Emission Part				
Item	Standard	Method	Requirement	Result
Conducted Emissions at Mains Terminals (150kHz-30MHz)	EN IEC 61000-6-4:2019	CISPR 16-2-1	Table 4	Pass
Radiated Emissions (30MHz-1GHz)	EN IEC 61000-6-4:2019	CISPR 16-2-3	Table 3.1	Pass
Immunity Part				
Item	Standard	Method	Requirement	Result
Electrostatic Discharge	EN IEC 61000-6-2:2019	EN 61000-4-2:2009	4kV Contact Discharge 8kV Air Discharge	Pass
Radiated Immunity (80MHz-1GHz, 1.4GHz-6GHz)	EN IEC 61000-6-2:2019	EN IEC 61000-4-3:2020	10V/m, 80%, 1kHz Amp. Mod. 3V/m, 80%, 1kHz Amp. Mod.	Pass
Electrical Fast Transients/Burst at Power Port	EN IEC 61000-6-2:2019	EN 61000-4-4:2012	2kV 5/50ns Tr/Td 5kHz Repetition Frequency	Pass
Electrical Fast Transients Burst at Signal Port	EN IEC 61000-6-2:2019	EN 61000-4-4:2012	1kV 5/50ns Tr/Td 5kHz Repetition Frequency	Pass
Surge at Power Port	EN IEC 61000-6-2:2019	EN 61000-4-5:2014+A1:2017	1.2/50µs Tr/Td 1kV Line to Line 2kV Line to Ground	Pass
Conducted Immunity at Power Port (150kHz-80MHz)	EN IEC 61000-6-2:2019	EN 61000-4-6:2014	10Vrms (emf),80%,1kHz Amp. Mod.	Pass
Conducted Immunity at Signal Port (150kHz-80MHz)	EN IEC 61000-6-2:2019	EN 61000-4-6:2014	10Vrms (emf),80%,1kHz Amp. Mod.	Pass
Voltage Interruptions	EN IEC 61000-6-2:2019	EN 61000-4-34:2007+A1:2009 (>16A)	For 50Hz 0 % UT for 250cycles UT is Supply Voltage	Pass

N/A: Not applicable